



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

April 9, 2008

DALMARAY CONCRETE PRODUCTS, INC
AARON AUSEN
405 S ARCH ST
JANESVILLE WI 53548

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: DALMARAY CONCRETE PRODUCTS, INC
Product Name: SEDIMENTATION TANK
Model Number(s): 46 GAL.
Product File No: 20080194

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed downstream of adequately sized POWTS treatment tank(s).
- This product is not required to have a baffle installed on the inlet.
- This product must have an approved effluent filter installed on the outlet.

This approval supersedes the approval issued on 6/20/2007 under product file number 20070275. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070275.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov